

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 74313  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38927

1. OWNER Hammond Homes & Construction ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1780 Lattin Road 4095 Raven Drive, Fallon, NV 89406  
 Fallon, NV 89406

2. LOCATION NE 1/4 NW 1/4 Sec. 27 T 19N N/S R 28E E Churchill County  
 PERMIT NO. 08-281-47 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material     | Water Strata | From | To | Thickness |
|--------------|--------------|------|----|-----------|
| Brown Sand   |              | 0    | 14 | 14        |
| Brown Clay   |              | 14   | 18 | 4         |
| Brown Sand   |              | 18   | 40 | 22        |
| Gray Sand    |              | 40   | 57 | 17        |
| Brown Gravel | X            | 57   | 70 | 13        |

8. WELL CONSTRUCTION  
 Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 70 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8              | 14.96               | .188                    | 0           | 10        |
| 6 PVC              | 3.92                | .258                    | 0           | 70        |

Perforations:  
 Type perforation saw Cut  
 Size perforation 1/8  
 From 65 feet to 68 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 60  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 60 feet to 70 feet

9. WATER LEVEL  
 Static water level 12.4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed Wayne Parson  
 By driller performing actual drilling on-site or contractor  
 Date 9-11-98

Date started 8/17/98, 19\_\_\_\_  
 Date completed 8/17/98, 19\_\_\_\_

7. WELL TEST DATA

| TEST METHOD:   | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>40</u> |                               | <u>1 hr.</u> |