WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74676
Permit No.
Basin 64

NOTICE OF INTENT NO. 2835 I

1. OWNER Dave Itza
MAILING ADDRESS 255 E. 2nd St.
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION
For: Jimmie Lee Fouts 315 Buena Vista
Battle Mountain, NV 89820 Lot 4 Blk D

2. LOCATION ____ 1/4 ____ 1/4 Sec. 24 T 32N N/S R 44 E Lander County
PERMIT NO. ____ (Issued by Water Resources) | 11-040-36 (Parcel No.) | Parcel D (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	9	9
Sand & gravel		9	24	15
Gray clay		24	83	59
Brown Clay		83	97	14
Sand & gravel		97	120	23

RECEIVED 97 MAR 18 AM 11:06 STATE ENGINEERS OFFICE

Date started 3/4/97 , 19__
Date completed 3/4/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		1 1/2

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3-14-97