


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 74692

Permit No. _____

Basin _____



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40132

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **Frank Woolsey**
 MAILING ADDRESS **2161 W Williams #280**
Fallon, NV 89406

ADDRESS AT WELL LOCATION **4145 Raven Drive,**
Fallon, NV 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 27 T 19N N/S R 28E E Churchill County
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 8-281-51 Subdivision Name _____

3. WORK PERFORMED

- New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE

- Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

- Cable Rotary RVC
 Air Other

LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	10	10
Brown Clay		10	13	3
Brown Sand		13	18	5
Brown Clay		18	22	4
Brown Sand		22	36	14
Brown Clay		36	40	4
Gray Sand		40	58	18
Brown Sand		58	69	11

8. WELL CONSTRUCTION

Depth Drilled 69 Feet Depth Cased 69 Feet

HOLE DIAMETER (BIT SIZE)

From 10 Inches To 69 Feet
 From 0 Feet To 69 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>14.96</u>	<u>.188</u>	<u>0</u>	<u>10</u>
<u>6</u>	<u>3.92</u>	<u>.258</u>	<u>0</u>	<u>69</u>

Perforations:

Type perforation Saw Cut

Size perforation 1/8

From 66 feet to 69 feet
 From _____ feet to _____ feet

Surface Seal: Yes No

Seal Type:

Depth of Seal 60

- Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped

Poured

Gravel Packed: Yes No

From 60 feet to 69 feet

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow 9' G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contractor

Address P.O. Box 1264

Contractor

Fallon, Nv. 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed _____

By driller performing actual drilling on-site or contractor

Date 3/1/99

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>		<u>1hr</u>

Date started 2/12/98 _____
 Date completed 2/12/98 _____