

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 74863  
 Permit No. 87  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 40315

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER George Hery ADDRESS AT WELL LOCATION Hidden Creek Rd (5000)  
 MAILING ADDRESS 2155 Canyon Point Court Palamino Valley Ca. 41 12.2.1.3 913  
Sparks, NV 89431

2. LOCATION NW 1/4 NE 1/4 Sec. 12 T 22N N/S R 21E E WASHOE County  
 PERMIT NO. 077-110-28 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN D.G.		0	2	
BROWN CLAY		2	5	3
BROWN D.G.		5	15	10
BROWN CLAY WITH MULTI COLORED VOLCANIC ROCK		15	25	10
GREEN CLAY		25	40	15
BROWN AND WHITE CLAY WITH MULTI COLORED VOLCANIC ROCK		40	50	10
GREEN AND BROWN VOLCANIC ROCK		50	97	47
FRACTURED MULTI COLORED VOLCANIC ROCK		97	100	3
GRAY AND GREEN VOLCANIC ROCK		100	115	15
BLACK AND GREEN VOLCANIC ROCK		115	130	15
GRAY AND GREEN VOLCANIC ROCK		130	170	40
BROWN CLAY MULTI COLORED VOLCANIC ROCK		170	180	10
GREEN VOLCANIC ROCK		180	190	10
GRAY CLAY BALLS WITH MULTI COLORED VOLCANIC ROCK		190	195	5
ROCK FRACTURED		200	239	39
RED VOLCANIC ROCK		239	240	1
T.D. 240'		240		

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
10 5/8 Inches	0	50	Feet
8 1/2 Inches	50	240	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.0	.225	+ 1 1/2	240

Perforations:  
 Type perforation FACTORY SAWED  
 Size perforation 3/32X3

From	To	feet to
220	240	feet
		feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 240 feet to 50 feet

9. WATER LEVEL  
 Static water level 70' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. PUMP & WELL SERVICE, INC. Contractor  
 Address PO BOX 60130 Contractor  
RENO, NV 89506  
 Nevada contractor's license number issued by the State Contractor's Board 2066  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 35387-A  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 3/25/99

Date started 3/19/99, 19\_\_\_\_  
 Date completed 3/23/99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 HOURS</u>