

Faxed 3-8-99

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 74949
Permit No.
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18461

1. OWNER IKE KUIAVER ADDRESS AT WELL LOCATION _____
MAILING ADDRESS Pahrump Lot 12 Pioche Street
2. LOCATION NE 1/4 NE 1/4 Sec. 2 T. 21 N/S R. 53 E E Nye County _____
PERMIT NO. 44-162-02 gamelund Subdivision Name _____
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	5	5
Calichia		5	9	4
grey clay		9	15	6
Calichia		15	19	4
grey clay		19	40	21
Brown clay	X	40	110	70
Calichia	X	110	113	3
Light brown clay	X	113	140	27

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
12 Inches 0 Feet 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	0	Sch. 40	0	140

Perforations:
Type perforation Factory
Size perforation Saw 1 1/8 x 5
From _____ feet to _____ feet
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

Date started 2-15 1999
Date completed 2-20 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	30	0	1/2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Water Well Service Contractor
Address P.O. Box 3392 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Water
By driller performing actual drilling on site or contractor
Date 3-4-99