

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16957

1. OWNER Tig & Maryanna Latham ADDRESS AT WELL LOCATION 6220 Iron Mountain Rd. Las Vegas, Nev. 89131
 MAILING ADDRESS Same

2. LOCATION SW 1/4 NE 1/4 Sec. 11 T. 19S N/S R. 60 E Clark County _____
 PERMIT NO. 125-11-502-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------|-----|------------|
| Caliche | | 600 | 715 | |
| Clay & Water | xx | 715 | 745 | |
| Clay | | 745 | 810 | |
| Clay & Gravel & Water | | 810 | 825 | |
| Clay | | 825 | 850 | |
| Gravel Clay & Water | | 850 | 900 | |

8. WELL CONSTRUCTION
 Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)
 From To
7 7/8 Inches 600 Feet 900 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 5 1/2 | Plastic | SRD21 | 560 | 900 |

Perforations:
 Type perforation Saw Tool
 Size perforation 1/8 x 4 row
 From 800 feet to 820 feet
 From 840 feet to 860 feet
 From 880 feet to 900 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet


9. WATER LEVEL
 Static water level 172 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
 Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89149

Nevada contractor's license number 10062 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller

Signed V. H. Dimick
 By driller performing actual drilling on site or contractor
 Date 4-2-99



Date started 3/10/99 19____
 Date completed 3/17/99 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |