WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75246
Permit No.
Basin 79

NOTICE OF INTENT NO. 22917

1. OWNER Rod Campbell
MAILING ADDRESS 920 Oxford
Sparks, NV 89431

ADDRESS AT WELL LOCATION
320 Appaloosa Circle
Reno, NV 89506

2. LOCATION NW ¼ SW ¼ Sec 4 T 23 (N)/S R 18 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) | 078-221-13 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sandy clay		0	107	
Gray sandy clay		107	140	
Lt. Brown clay		140	158	
gray sandy clay		158	184	
Lt. Brown sandy clay		184	290	
firm DG		290	313	
Granite	x	313	340	

RECEIVED 99 MAY 25 AM 9:52 STATE ENGINEER'S OFFICE

Date started 2-25-99, 19
Date completed 2-27-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	25	310	3

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 ¼ Inches		0 Feet	19 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	14	.188	-1	340

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3"
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50+
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 340 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MILLER & SONS DRILLING CO. (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 037915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 4-16-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627