WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75654
Permit No.
Basin 212

NOTICE OF INTENT NO. 18260

1. OWNER S. NEVADA WATER AUTHORITY
MAILING ADDRESS 1900 E. FLAMINGO Rd Ste 190 LAS VEGAS NV 89119
ADDRESS AT WELL LOCATION 1ST 2S DEWATERING WELLS N. OF SAHARA BLVD.

2. LOCATION SE ¼ Sec. 10 T. 21S N/S R. 62 E. CLARK County
PERMIT NO. OW 10889 B (Issued by Water Resources) 161-10-802-002 (Parcel No.) GRANITE CONST. (Subdivision Name)

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Dewatering

6. 1-2S 1st Geid LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1- Top Soil		0	5	
2- Brown clay	20	5	21	
3- white clay	20	21	30	
4- Brown clay	20	30	40	

Date started ..., 19..
Date completed ..., 19..

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	10 GPM	2 FT	2

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Sch 40	4"	PVC	0	40

Perforations:
Type perforation Factory Slot
Size perforation .020
From 20 feet to 40 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) FOOTHILL ENG. & DEWATERING
Address (Contractor) 905 E. 3rd St. CORONA, CA 71917
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1645T-1
Signed (By driller performing actual drilling on site or contractor)
Date 9-21-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627