WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Dewatering

OFFICE USE ONLY
Log No. 76033
Permit No.
Basin 212

NOTICE OF INTENT NO. 18260

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1900 E. Flamingo Rd Ste. 170 Las Vegas, NV 89119
ADDRESS AT WELL LOCATION Sahara Rd - Sloan Wash

2. LOCATION SE ¼ Sec. 10 T. 21S N/S R. 62 E. Clark County
PERMIT NO. DW 10894 (Issued by Water Resources) 161-10-802-004 (Parcel No.) Granish Const. (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other Dewatering

4. PROPOSED USE: [ ] Domestic [X] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE Dewatering: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other Dewatering

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top Soil		0	5	
compacted clay				
Brown clay	11	5	34	
white clay	11	34	55	
Sand & Gravel water strata	11	55	59	
Brown clay	11	59	75	

Received APR 26 1999

Date started 7-15, 19 98
Date completed 7-15, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
pit	50		1 HR.

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	75 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	Sch	40 PVC	0	70

Perforations:
Type perforation Factory Slot
Size perforation .020
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 70 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foot Hill Eng & Drilling (Contractor)
Address 905 E 3rd St (Contractor)
Corona CA 91717
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1645-T1
Signed (By driller performing actual drilling on site of contractor)
Date 7-15-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627