WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76085
Permit No. 44724
Basin 204

NOTICE OF INTENT NO. 19459

1. OWNER NATIONAL Mustang ASSOCIATION
MAILING ADDRESS Box 1367
CEDAR City, ~~Utah~~ UTAH 84721

ADDRESS AT WELL LOCATION 2 MILES NORTH of CALIENTE ALONG RAILROAD TRACKS

2. LOCATION N/W ¼ NE ¼ Sec. 14 T. 4 N ⊗ R. 67 E. LINCOLN County
PERMIT NO. 44724 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This was a very old well with 12" surface pipe unknown how deep.				
It had 6" casing that was very poor condition but I was unable to pull it				
I believe the casing at water level was completely gone or was never set to bottom from looking down the well with a mirror				
Neat cement was pumped from bottom of well to surface to seal well				
There was only 24" of water in well				

DCNR/DWR Received JUL 9 1999 LAS VEGAS OFFICE

Date started 7-1-99, 19
Date completed 7-1-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.156	0	unknown

Perforations:
Type perforation unknown
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address P.O. Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 7-6-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627