WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76088
Permit No.
Basin 212

NOTICE OF INTENT NO. 18519

1. OWNER Hydrotech c/o The Walters Groups
MAILING ADDRESS 5500 E. Flamingo Road
Las Vegas, NV 89122

ADDRESS AT WELL LOCATION Desert Pines Golf Course, 3415 East Bonanza Road, Las Vegas, NV 89101

2. LOCATION NW 1/4 NE 1/4 Sec. 36 T T20S N/S R R61E E Clark County
PERMIT NO. Issued by Water Resources
139-36-502-003 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Sandy clay		0	5	5
Fat clay		5	20	15
Sandy clay		20	30	10

Date started 5/11/1999, 19__
Date completed 5/11/1999, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	30

Perforations:
Type perforation Factory slot
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-1'/1-3' Bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 3 feet to 30 feet

9. **WATER LEVEL**
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High c/o Converse Consultants
Contractor
Address 731 Pilot Road, Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed
By driller performing actual drilling on-site or contractor
Date 6/28/1999

USE ADDITIONAL SHEETS IF NECESSARY