WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76124
Permit No.
Basin 212

NOTICE OF INTENT NO. 15713-[illegible]

1. OWNER Dollar Rent a Car
MAILING ADDRESS 4775 S Swenson
Las Vegas Nev

ADDRESS AT WELL LOCATION 4775 S Swenson
Las Vegas, Nev

2. LOCATION S ½ SW ¼ Sec 22 T 21 N/S R 61 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 16222402002 | Subdivision Name NONE

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 6" | 6" |
| Subgrade | | 6" | 18" | 1' |
| Sandy Silt w/L gravel | | 18" | 5' | 3.5' |
| Caliche | | 5' | 7' | 2.0' |
| Sandy Clay Silt | | 7' | 10' | 3.0' |
| Caliche | | 10' | 12' | 2.0' |
| Silty Sand w/Gravel | 13' | 12' | 30' | 18.0' |

Date started Aug 18, 1998
Date completed Aug 18, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6 Inches | 30 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 1/4 | | 1/4" | 0 | 30 |

Perforations:
Type perforation Factory Slotted
Size perforation 020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 30 feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Compliance Drilling (Contractor)
Address P.O. Box 94136 (Contractor)
Las Vegas Nev. 89193
Nevada contractor's license number issued by the State Contractor's Board 387
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2057
Signed [signature] By driller performing actual drilling on site or contractor
Date Aug 20 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627