WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76305
Permit No.
Basin 212

NOTICE OF INTENT NO. 15713-2wells

1. OWNER Dollar Rent A Car
MAILING ADDRESS 4775 S. Swenson
Las Vegas, Nev
ADDRESS AT WELL LOCATION

2. LOCATION S ½ SW ¼ Sec 22 T 21 S/S R 61 E CLARK County
PERMIT NO. (Issued by Water Resources) 16222402002 (Parcel No.) NONE (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	6"	0.5'
Subgrade		6"	18"	1.0'
Sandy Silt w/ Gravel		18"	5'	3.5'
Caliche		5'	7'	2.0
Sandy Clay Silt		7'	9'	2.0'
Caliche		9'	11.5	2.5'
Silty Sand w/gravel	13'	11.5	30'	18.5'

WC11 01

Received APR 6 1999

AUG 9

Date started Aug 18, 19 98
Date completed Aug 18, 19 98

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/4		1/4	0	30

Perforations:
Type perforation Factory Slotted
Size perforation 020
From 10 feet to 30 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 6
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 30 feet

9. WATER LEVEL

Static water level 73 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Compliance Drilling (Contractor)
Address P.O Box 94136 (Contractor)
Las Vegas, Nev. 89136
Nevada contractor's license number issued by the State Contractor's Board 3507
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2057
Signed ____ (By driller performing actual drilling on site or contractor)
Date Aug 20 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627