WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 76309
Permit No.
Basin 212

NOTICE OF INTENT NO. 12938

1. OWNER LAS VEGAS HILTON CORP.
MAILING ADDRESS 3000 PARADISE RD.
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 3000 PARADISE RD.
LAS VEGAS, NV 89109

2. LOCATION - ¼ W1/2 ¼ Sec. 10 21 N/S R. 61 E. CLARK County
PERMIT NO. DW1088 (Issued by Water Resources) 62-103-020-01 (Parcel No.) 162-10-302-001 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandon well #1 4 of 12 | | | | |
| Filled with 3 1/2 yards slurry | | | | |
| cement mix. | | | | |
| Excavated to depth, pulled | | | | |
| casing, drilled out gravel. | | | | |

Date started 10-19, 1998
Date completed 10-19, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24" Inches | 0 Feet | 30 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | .250 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4 x 2 1/2
From feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2043
Signed (By driller performing actual drilling on site or contractor)
Date 11-30-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627