WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76326
Permit No.
Basin 105

NOTICE OF INTENT NO. 36780

1. OWNER Pacific Westmark
MAILING ADDRESS P.O. Box 783
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 430 Rabbit Brush Gardnerville NV.

2. LOCATION NW ¼ NE ¼ Sec. 1 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 23-473-42 | Subdivision Name Wild Flower

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravel		0	16	16
Sandy Clay Br.		16	43	27
Med. Gravel		43	76	33
Br. Sandy Clay		76	134	58
Gravel & Boulders		134	255	121
Gray Sandy Clay		255	638	383
Gray Sand	✓	638	646	8
Gray Clay		646	660	14
Gray Coarse Sand	✓	660	670	10
Gray Clay		670	675	5

RECEIVED 99 JUN -2 PM 1:05 STATE ENGINEER'S OFFICE

Date started 5-10, 1999
Date completed 5-28, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2 1/2

8. WELL CONSTRUCTION
Depth Drilled 675 Feet Depth Cased 675 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	60 Feet
9 7/8	Inches	60 Feet	675 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16 5/8	13	.188	+2	675

Perforations:
Type perforation Factory Milled
Size perforation 1/16 x 1/3 - 6 Row
From 635 feet to 675 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 675 feet

9. WATER LEVEL
Static water level 217 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality No test

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-28-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627