

OFFICE USE ONLY  
Log No. 76329  
Permit No. 105  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34467

1. OWNER R. EATON ADDRESS AT WELL LOCATION 1391 Suckwheat  
MAILING ADDRESS 114 Hwy 395 So. GV, NV 89123 GV, NV 89410  
2. LOCATION NW 1/4 NE 1/4 Sec. 1 T 12 NS R 20 E DOUGLAS County  
PERMIT NO. 2348229 WINDFLOWER Subdivision Name  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay loam		0	6	6
Clay w some sand, cobbles + gravel		6	83	77
More sand + gravel, less clay		83	160	77
Sand, clay, cobbles + gravel	X	160	210	50
More small gravel less clay		210	230	20

8. WELL CONSTRUCTION  
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 53 Feet  
Inches Feet Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>0.180</u>	<u>42</u>	<u>230</u>

Perforations:  
Type perforation SAWCUT  
Size perforation 3 X 7/32  
From 190 feet to 230 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 53  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 53 feet to 230 feet

9. WATER LEVEL  
Static water level 76 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COOL °F Quality ✓

Date started 3/26 1999  
Date completed 4/1 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20-30</u>	<u>-</u>	<u>3</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name NEVADA DRILLING Contractor  
Address 75 LEWERS CRK RO Contractor  
WASHOE VALLEY, NV 89704  
Nevada contractor's license number 13697A  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 1790  
Division of Water Resources, the on-site driller.  
Signed Joe Leisch  
By driller performing actual drilling on site or contractor  
Date 4/7/99