WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76330
Permit No.
Basin 105

NOTICE OF INTENT NO. 39838

1. OWNER James Kashuba
MAILING ADDRESS 1457 Edlesborough Circle
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION Lot 20, Out-R-Way,
Gardnerville, NV 89410

2. LOCATION NW 1/4 SW 1/4 Sec. 3 T 12N N/S R 21E E Douglas County
PERMIT NO. (Issued by Water Resources) 35-370-06 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and cobbles		0	4	4
Brown ryhlite		4	65	61
Sandstone		65	74	9
Sandy clay		74	102	28
Sandstone		102	180	78
Limestone	x	180	220	40

RECEIVED
99 JUN 28 AM 11:10
STATE ENGINEER'S OFFICE

Date started 6/18/99, 19__
Date completed 6/22/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75+		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0'	Feet	220'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	2+	220

Perforations:
Type perforation Factory sawed
Size perforation 3/32 x 3
From 188' feet to 208' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 220 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 6/23/99

USE ADDITIONAL SHEETS IF NECESSARY