

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 76339  
 Permit No. 105  
 NOTICE OF INTENT NO. **39833**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

OWNER Norm Denny  
 MAILING ADDRESS 1905 Eldon Way  
Gardnerville, NV 89410  
 ADDRESS AT WELL LOCATION 1905 Eldon Way,  
Gardnerville, NV 89410  
 2. LOCATION NE 1/4 NW 1/4 Sec. 13 T 13N N/S R 20E E DOUGLAS County  
 PERMIT NO. 23-270-63 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	6	6
Sandy clay		6	15	9
Brown clay		15	25	10
Sand		25	40	15
Clay & Gravel		40	65	25
Sand & small gravels		65	75	10
Brown clay		75	95	20
Sand & 3/8" gravels		95	110	15
Brown clay		110	130	20
Sand		130	133	3
Sandy brown clay		133	156	23
Sand & fine gravel		156	195	39
Brown clay		195	201	6
Sand & fine gravel	xx	201	262	61
Brown clay		262	265	3

8. WELL CONSTRUCTION  
 Depth Drilled 265 Feet Depth Cased 265 Feet  
 HOLE DIAMETER (BIT SIZE)  

Inches	From	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>265</u>	<u>265</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>265</u>

Perforations:  
 Type perforation Factory mill slot  
 Size perforation 3/32 x 3"  
 From 200 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 265 feet

9. WATER LEVEL  
 Static water level 125 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature cool °F Quality not tested

Date started 4/19/99, 19\_\_\_\_  
 Date completed 5/3/99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>100+</u>		<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 5/4/99