

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22811

1. OWNER RIVERSIDE, INC ADDRESS AT WELL LOCATION RIVERSIDE Electric
 MAILING ADDRESS PO Box 720 4000 W. WINNEMUCCA BLVD
PARMA, ID 83660 WINNEMUCCA, NV 89445
 2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 1 T. 35 N S R. 37 E Humboldt County
 PERMIT NO. 59794 Parcel No. 1 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1'
SANDY SOIL		1	2	1'
SOIL		2	5	3'
FINE SAND		5	16	11'
BROWN CLAY		16	19	3'
SAND + GRAVEL		19	67	48'
SAND + CLAY layers		67	100	33'
SAND + GRAVEL		100	137	37'

8. WELL CONSTRUCTION
 Depth Drilled 137 Feet Depth Cased 137 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 100 Feet
6 Inches 100 Feet 137 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>19.05</u>	<u>.250</u>	<u>+3</u>	<u>137</u>

Perforations:
 Type perforation AIR PERFORATION
 Size perforation 1/4"
 From 105 feet to 126 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 56 °F Quality Good

Date started 7-12 19 99
 Date completed 7-15 19 99

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>150</u>	<u>N/A</u>	<u>4 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RIVERSIDE, INC Contractor
 Address PO Box 720 Contractor
PARMA, ID 83660
 Nevada contractor's license number issued by the State Contractor's Board 0044881
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1918
 Signed Dane Cleem
 By driller performing actual drilling on site or contractor
 Date 7/19/99