


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 76355
 Permit No. 49
 Basin



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Eliseo Castaneda
 MAILING ADDRESS 609 Market St ETKO NV

NOTICE OF INTENT NO. 39328
 ADDRESS AT WELL LOCATION 1st 6 blocks A 1st Chance Ranch Unit 3

2. LOCATION NE 1/4 SE 1/4 Sec 12 T 34 N S R 55 E ETKO County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvium</u>		<u>0</u>	<u>20</u>	
<u>Ben Silty Gravels</u>		<u>20</u>	<u>100</u>	
<u>Sandstone</u>	<u>101</u>	<u>110</u>	<u>115</u>	<u>12'</u>
<u>Gravel & Sand</u>	<u>127</u>	<u>115</u>	<u>145</u>	<u>6'</u>
<u>Ben Silty</u>		<u>145</u>	<u>150</u>	

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 176 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 180 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>7913</u>	<u>788</u>	<u>0</u>	<u>176</u>

Perforations:
 Type perforation Factory slots
 Size perforation 1/4"
 From 126 feet to 176 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 180 feet to 50 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow 22 G.P.M. 150 P.S.I.
 Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling & Equipment Contractor
 Address PO Box 2487 ETKO NV Contractor
89403
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1670
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-20-99

Date started 6-16
 Date completed 6-19 1999

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	Bailer	Pump	
G.P.M.	Draw Down (Feet Below Static)		
<u>22</u>			