WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76370
Permit No.
Basin 110A

NOTICE OF INTENT NO.

Circle Bar N Ranch - Tom Reuigzio

1. OWNER B L M - Reservation well
MAILING ADDRESS P.O. Box 1576
Sparks NV 89432

ADDRESS AT WELL LOCATION Reservation well
SE¼ SE¼ Sec 20 14N R22E
Project # 536

2. LOCATION SE ¼ SE ¼ Sec. 20 T. 14N N/S R. 22 E. Lyon County
PERMIT NO. Project # 536 (Issued by Water Resources) — (Parcel No.) BLM Land (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Old well 6¼				
T.D. approx				
255' deep				
Drilled Rust	5gpm	241	255	14
Clay & Sand		255	265	10
Fractured Rock	X	265	270	5
(Loss mud circulation)				
Fractured Rock	X	270	295	25
air drill				
Rock Small -				
Fracture		295	300	5

RECEIVED 99 JUN 30 AM 11:54 STATE ENGINEERS OFFICE

Date started 11-28, 19 98
Date completed 11-30, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
air lift	30	300'	1 HR
		air line	
Pump	20	5' approx	1 HR

8. WELL CONSTRUCTION
Depth Drilled 255 to 300 Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6¼ Inches	255 Feet	300 Feet
6¼ Inches	255 Feet	265 Feet mud
6¼ Inches	265 Feet	300 Feet air

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 O.D.		.188	180	300
Flared Top	of Casing -	Cone	Bottom	
of Casing				

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 5 Rows
From 200 feet to 220 feet
From 240 feet to 260 feet
From 280 feet to 300 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal Unknow
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No Unknow
From feet to feet

9. WATER LEVEL
Static water level 204' 6" feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-15-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627