

OFFICE USE ONLY
 Log No. 6373
 Permit No. 33061
 Basin 173B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35996

1. OWNER Sharp Ranch
 MAILING ADDRESS HCR 76 Box 900
Via Tonopah, NV 89049
 ADDRESS AT WELL LOCATION 6 miles north of
Nyala Ranch
 2. LOCATION SE 1/4 SE 1/4 Sec. 34 T 6 N7S R 56 E Nye County
 PERMIT NO. 33061 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Sand & Gravel		2	10	8
Sand Clay & Gravel		10	20	10
Large Gravel & Sand		20	40	20
Brown Clay & Gravel		40	50	10
Sand & Gravel	x	50	60	10
Clay		60	70	10
Clay & small Gravel		70	90	20
Sand & Gravel	x	90	140	50
White Clay & Gravel		140	150	10
Sand & Gravel		150	180	30
Clay sand & Gravel		180	210	30
Cemented Sand & Gravel	x	210	265	55
Brown Clay & Gravel		265	275	10
Cemented Sand & Gravel	x	275	362	87
Gravel & clay		362	380	18
Brown clay & Gravel	x	380	390	10
Hard Yellow clay		390	400	10

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 60
28 Inches 0 Feet 60 Feet
 From 60 To 400
20 Inches 60 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	52.73	.250	0	60
16	42.05	.250	0	400

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 16 rows
 From 95 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 400 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Good

Date started April 1, 1999
 Date completed April 29, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>900</u>	<u>324</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Raymond Lewis By Responsible D. Christiansen
 By driller performing actual drilling on site or contractor
 Date May 25, 1999

RECEIVED
 99 MAY 28 AM 11:04
 STATE ENGINEERS OFFICE