

OFFICE USE ONLY
Log No. 76376
Permit No. #184
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40001

1. OWNER Paul Fava ADDRESS AT WELL LOCATION Sacramento Pass
MAILING ADDRESS 980 El Camio (46 Miles East of Ely)
Boulder City, NV 89005

2. LOCATION SE 1/4 SE 1/4 Sec 17 T 15 N8 R 68 E White Pine County
PERMIT NO. A.P.N. 12-740-02
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvial fill & Boulders		0	20	20
Clay & Gravel		20	40	20
Cemented Gravels		40	70	30
Fractured Limestone		70	100	30
Void		100	108	8
Limestone		108	160	52
Oxidized Fractured Limestone		160	170	10
Limestone		170	210	40
Fractured Limestone	x	210	215	5
Limestone		215	230	15
Fractured Limestone	x	230	235	5
Limestone		235	265	30

8. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches To 0 Feet 265 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	265

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 rows
From 201 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 ft. Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 265 feet

9. WATER LEVEL
Static water level 167 feet below land surface
Artesian flow cold G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. Contractor
Address 557 Ely Avenue Contractor
Ely, Nevada 89301
Nevada contractor's license number 14790 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Jerold D. Christiansen
By driller performing actual drilling on site or contractor
Date July 21, 1999

Date started May 28, 1999
Date completed June 29, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	30	93	1 1/2

RECEIVED
59 JUL 26 AM 11:12
STATE ENGINEERS OFFICE