


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



1. OWNER **TRI Water**
MAILING ADDRESS **9575 Double R Blvd**
Reno NV

ADDRESS AT WELL LOCATION

2. Location **1/4 SW 1/4 SE Sec 36 T 20N R 22E** Storey County
PERMIT NO. **M/O-1187** PARCEL NO. **04-090-15** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well | Replace | Recondition | Domestic | Irrigation | Test | Cable | Rotary | RVC
 Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other | Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & volcanic rocks.		0	57	57
Volcanic rock.		57	500	443

8. WELL CONSTRUCTION

Depth Drilled **500 feet** Depth Cased **500 feet**
 HOLE DIAMETER (BIT SIZE)
 From To
 6 1/8 inches 0 feet 500 feet
 inches feet feet
 inches feet feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 pvc	.932	.218	+1 1/2	500

Perforations:

Type Perforation	Factory
Size perforation	.020 screen
From 260 feet to	460 feet
From feet to	feet
From feet to	feet
From feet to	feet
From feet to	feet

Surface Seal YES No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 500 feet

RECEIVED
 99 JUL 28 AM 10:19
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level **230** feet below land surface
 Artesian flow **0** GPM **0** P.S.I.
 Water Temperature **cold** Degrees F Quality

Date started **7-2 -99**
 Date completed **7-10 -99**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
		6		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **2121**
 Signed *Steve McKay*
 By driller performing actual drilling on site or contractor
 Date **7-16 -99**