

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40663

1. OWNER Bruce Homer ADDRESS AT WELL LOCATION 5296 Desert Hills Loop  
 MAILING ADDRESS Fallon, NV 89406  
 2. LOCATION NW 1/4 SW 1/4 Sec 20 T. 19 N/S R. 28 E Churchill County  
 PERMIT NO. 008-176-17 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>CLAY</u>		<u>5</u>	<u>12</u>	<u>7</u>
<u>SAND</u>		<u>12</u>	<u>45</u>	<u>32</u>
<u>CLAY</u>		<u>45</u>	<u>65</u>	<u>20</u>
<u>SAND</u>		<u>65</u>	<u>75</u>	<u>10</u>

8. WELL CONSTRUCTION  
 Depth Drilled 75 Feet Depth Cased 75 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 75 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>3.2</u>	<u>1.280</u>	<u>0</u>	<u>75</u>

 Perforations:  
 Type perforation slots  
 Size perforation 1/4 x 3"  
 From 70 feet to 75 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 70 feet to 75 feet  
 9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started 6-6 1999  
 Date completed 6-7 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>20</u>	<u>3</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Matthew Farris Drilling Contractor  
 Address P.O. Box 5205 Contractor  
Fallon, NV 89407  
 Nevada contractor's license number 43145 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 6-30-99