WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76409
Permit No.
Basin 67

NOTICE OF INTENT NO. 41619

1. OWNER CHRH
MAILING ADDRESS 201 Rosewood Dr.
Fernley, NV 89408

ADDRESS AT WELL LOCATION 1845 HighLand Dr. Fernley
Nv. 89408

2. LOCATION NE 1/4 SE 1/4 Sec. 36 T 20N N/S R 25E E Lyon County
PERMIT NO. Issued by Water Resources
21-501-32 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND AND GRAVEL		0	130	130
BROWN CLAY		130	170	40
SAND AND GRAVEL		170	220	50
BROWN CLAY		220	280	60
SAND AND GRAVEL	XX	280	300	20

RECEIVED 99 JUL 26 AM 11:12 STATE ENGINEER'S OFFICE

Date started 6/9/99 , 19__
Date completed 6/6/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		1 Hr

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.94	.188	0	10
6 pvc	3.92	.258	50	300

Perforations:
Type perforation saw cut
Size perforation 1/8 inch
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 254 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling,Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 6/19/99

USE ADDITIONAL SHEETS IF NECESSARY

I