WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76432
Permit No.
Basin 212

NOTICE OF INTENT NO. 19682

1. OWNER TIMET METALS
MAILING ADDRESS 8100 LAKE MEAD DR. HENDERSON NV.
ADDRESS AT WELL LOCATION 8100 LAKE MEAD DR HENDERSON NV.

2. LOCATION SW ¼ SW ¼ Sec. 12 T 22 N/S R 62 E CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 178 12 501 007 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL WAS NOT SET ACCORDING TO CODE. WELL HAD 15' OF SILT INSIDE				
WELL WAS OVER-DRILLED AND PULLED WITH 16" AUGER. CEMENT GROUT WAS TREMIED FROM 60' TO SURFACE.				

CNFD DWR OCT 17 1999

Date started 8-18, 19 99
Date completed 8-18, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		3/16	0	60

Perforations:
Type perforation PVC
Size perforation .020
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 23
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 28 feet to 60 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS SPILOTRO (Contractor)
Address 1016 KATELLA AVE (Contractor)
ANAHEIM CA 92805
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2129
Signed Thomas J Spilotro (By driller performing actual drilling on site or contractor)
Date 8-25-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627