

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **76435**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18887**

1. OWNER **Nolcini** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **4581 W. Rancho Ave** **4581 W. Rancho Ave**
Pahrump, NV 89048

2. LOCATION **SE 1/4 SW 1/4 Sec. 23 T 20S N/S R 52E E Nye** County
 PERMIT NO. **28-463-07** **Rancho Vista Estates** Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	4	4
grey clay		4	18	14
light green clay		18	22	4
white clay		22	27	5
brown clay		27	31	4
green clay	x	31	53	22
light green clay	x	53	65	12
white clay with caleche	x	65	112	47
See next line	x	112	140	28
light green clay with caleche strings				

8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
11	0	140	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **120** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL

Static water level **51** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

Date started **7/13/99**, 19____
 Date completed **7/13/99**, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **7.24.99**

SEP 15 2009

