RMW-1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76509
Permit No.
Basin 212

NOTICE OF INTENT NO. 19027

1. OWNER Rebel Oil
MAILING ADDRESS 1720 West Charleston Las Vegas, Nevada
ADDRESS AT WELL LOCATION 1720 West Charleston Las Vegas, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 33 T. 20 N/S R. 61 E. Clark County
PERMIT NO. — Issued by Water Resources | 139-33-406-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Material		0	4	
Brown silty sand trace coarse sands, graded		4	10	
little clays		10	12	
White to gray silty sand some coarse sands, little clays		12	15	
Caliche		15	17	
White to gray silty sand sand some coarse sands, little clays		17	23	
Caliche		23	24	

Date started 7/20, 1999
Date completed 7/20, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 24 Feet Depth Cased 4 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	24 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	—	—	0	4

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 4 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 24 feet

9. WATER LEVEL
Static water level 13.22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Vude Companies Contractor
Address 301 West Deer Valley Road #7 Contractor
Phoenix, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M207071
Signed Larry Lopez
By driller performing actual drilling on site or contractor
Date 8/26/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627