

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18891

1. OWNER **CR Homes/Gainley** ADDRESS AT WELL LOCATION **3861 S. Unicorn**
 MAILING ADDRESS **3861 S. Unicorn**
Pahrump, NV 89048

2. LOCATION **SW 1/4 SW 1/4 Sec. 35 T 20S N/S R 53E E Nye** County **Nye**
 PERMIT NO. **41-121-11** Parcel No. **Calvada Valley** Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	3	3
brown caleche		3	10	7
brown clay		10	15	5
See next line		15	22	7
light brown clay with caleche stringsx				
See next line		22	29	7
brown clay with caleche strings				
See next line		29	36	7
light brown clay with brown caleche strings				
See next line	x	36	140	104
brown clay with caleche strings				

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **120** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **64** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *James Strickland*
 By driller performing actual drilling on-site or contractor
 Date **8.7.99**

Date started **7/15/99** 19____
 Date completed **7/15/99** 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)