WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.350

OFFICE USE ONLY
Log No. 76570
Permit No.
Basin 104

NOTICE OF INTENT NO. 38887

1. OWNER Shepards of the Sierra Lutheran Church
MAILING ADDRESS PO Box 2705 Carson City NV 89702
ADDRESS AT WELL LOCATION 3608 N Hwy 395 Gardnerville NV 89423

2. LOCATION SE ¼ NW ¼ Sec. 6 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. ~~64049~~ 64042 (Issued by Water Resources) | 13-031-07 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles and Boulders		0	78	78
DG Sands				
DG Sand Rusty		78	110	32
Coarse DG Sands		110	169	59
and Clay				
Hard Granite		169	245	76
DG Sands				
DG Sands and Clay		245	300	55
Strata Rusty Clay				
Fractured DG Granite	XX	300	340	40

Date started 4-9, 19 99
Date completed 4-13, 19 99

RECEIVED 99 APR 28 AM 8:44 STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22-25	80	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	340 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	340

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 340 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. 22 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat Drive Carson City NV 89706 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 21775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-17-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627