WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76573
Permit No.
Basin 105

NOTICE OF INTENT NO. 38849

1. OWNER Blain McGuire Construction
MAILING ADDRESS Washoe Valley NV
ADDRESS AT WELL LOCATION 2663 Kayne Minden NV 89423

2. LOCATION SW ¼ NE ¼ Sec 34 T 14 ☐S R 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 21-192-060 (Parcel No.) Johnson Lane Area (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Blow Sands		4	9	5
Course DG Sands		9	38	29
Brown Clay		38	64	36
Course Sands and obsidian Sands		64	93	29
Brown Solid Clay		93	135	42
Fractured Gravels Black Slate and Volcanics Sands	XXX	135	160	25

RECEIVED 99 MAY 26 AM STATE ENGINEER'S OFFICE

Date started 5-21, 1999
Date completed 5-22, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	35	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3x5/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. 25+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat Drive Carson City NV 89706 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael L Hack
(By driller performing actual drilling on site or contractor)
Date 5-23-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627