

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 76579
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39998

1. OWNER N.D.O.T. ADDRESS AT WELL LOCATION 5 miles north of Ely (McGill flat gravel pit)
 MAILING ADDRESS 1263 S. Stewart Street Carson City, NV 89712

2. LOCATION SE 1/4 NE 1/4 Sec. 26 T. 17 N&R. 63 E. White Pine County
 PERMIT NO. C - 194 Parcel No. _____ Subdivision Name _____
 Waiver Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 ~~Municipal~~ Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Sand & Gravel		2	10	8
Sand & Large Gravel	x	10	25	15
Sand & Small Gravel		25	40	15
Sand & Gravel		40	60	20
Course Gravel	x	60	65	5
Sand & Gravel		65	120	55
Brown Clay & Gravel		120	140	20
Course Gravel	x	140	145	5
Brown Clay & Gravel		145	160	15
Brown Clay		160	182	22

8. WELL CONSTRUCTION
 Depth Drilled 182 Feet Depth Cased 182 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 182 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	182

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 81 feet to 182 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 182 feet

RECEIVED
 99 MAY 28 AM 11:04
 STATE ENGINEERS OFFICE

Date started May 15, 1999.
 Date completed May 16, 1999.

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
175	140	1 1/2	

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date May 25, 1999