23

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

RTP-10
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76643
Permit No.
Basin 72

NOTICE OF INTENT NO. 39970

1. OWNER APOLLO GOLD
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION FLORIDA CANYON
MINESITE, 8 MILES SW OF IMLAY, NV.

2. LOCATION NE ¼ SW ¼ Sec 2 T 31 N/S R 33 E PERSHING County
PERMIT NO. N/A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
RED ROCK		0	20	20
LIGHT GRAY ROCK		20	60	40
DARK GRAY ROCK	240	60	245	185

RECEIVED 99 JUL 7 PM 2:38 STATE ENGINEER'S OFFICE

Date started MAY 25, 1999
Date completed MAY 26, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	20 Feet
6 1/2 Inches		20 Feet	245 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7 5/8	29	0.375	0	20
2 3/8	1.29	SCH. 80	+2	245

Perforations:
Type perforation MILL SLOT
Size perforation 0.020"
From 185 feet to 205 feet
From 225 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 245 feet

9. WATER LEVEL
Static water level 215 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 80 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1772

Signed Rod Aders
By driller performing actual drilling on site or contractor

Date MAY 26, 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627

B.ST.L