23

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

RTP-9
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7644
Permit No.
Basin 72

NOTICE OF INTENT NO. 39971

1. OWNER APOLLO GOLD
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION FLORIDA CANYON
MINESITE, 8 MILES SW OF IMLAY, NV.

2. LOCATION SE ¼ SW ¼ Sec. 2 T 31 N/S R 33 E PERSHING County
PERMIT NO. N/A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
RED ROCK		0	20	20
GRAY ROCK SOME		20		
BROWN	185		50	30
BLACK ROCK WITH		50		
WHITE	215		230	180

Date started MAY 24, 1999
Date completed MAY 25, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches	0 Feet	20 Feet	
6 1/2 Inches	20 Feet	230 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7 5/8	29	0.375	0	20
2 3/8	1.29	SCH. 80	+2	230

Perforations:
Type perforation MILL SLOT
Size perforation 0.020"
From 170 feet to 190 feet
From 210 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 230 feet

9. WATER LEVEL
Static water level 124' feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 90 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1772
Signed Rod Aders (By driller performing actual drilling on site or contractor)
Date MAY 25, 1999

RECEIVED 99 JUN -7 PM 2:38 WATER RESOURCES

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627