WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76662
Permit No.
Basin

NOTICE OF INTENT NO. 39366

1. OWNER Ed Baber
MAILING ADDRESS 3385 Fremont
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 3385 Fremont
Lot 11, Blk F

2. LOCATION S½ 1/4 ____ 1/4 Sec. 23 T 39 N/S R 38 E Humboldt County
PERMIT NO. ____ Issued by Water Resources | 06-172-11 Parcel No. | Ranchos Paradise Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	40	
Gravel/clay		40	50	10
clay		50	75	25
gravel		75	100	25
clay		100	120	20
sand & clay	x	120	140	20
sand & gravel	x	140	160	20

RECEIVED 99 JUN -8 AM 9:07 STATE ENGINEER'S OFFICE

Date started 5/22/99 , 19__
Date completed 5/23/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		3

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	60	Feet
9-7/8	Inches	60	Feet	160	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	150

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x 3
From 110 feet to 150 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 160 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154T-1
Signed [signature] By driller performing actual drilling on-site or contractor
Date 6/1/99