WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76323
Permit No. 107
Basin

NOTICE OF INTENT NO. 41660

1. OWNER Tom Clemens
MAILING ADDRESS
ADDRESS AT WELL LOCATION #17 Gainer Smith Valley

2. LOCATION 2 1/2 1/4 NE 1/4 Sec. 28 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources | 09-122-10 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil, Clay, Sand		1	7	
Sand, Gravel		7	86	
Clay		86	110	
Gravels		110	143	
Clay		143	210	
Gravel Sand		210	216	
Clay		216	283	
Gravels		283	288	
Clay	317	288	317	6"
Gravel	340	317	340	
Clay	345	340	345	
Gravels		~~345~~	~~[illegible]~~	
Clay	358	345	358	
		358	360	

RECEIVED 99 JUN 16 AM 10:19 STATE ENGINEERS OFFICE

Date started 5/17/99, 19
Date completed 5/21/99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60-65		4 hrs

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	188	1	20
6 7/4	3	Sch 40	20	360

Perforations:
Type perforation Mill Perf
Size perforation 3/16 x 6 x 8
From 340 feet to 360 feet
From ~~300~~ 220 feet to 330 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200 feet to 360 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pearl Drilling Contractor
Address PO 599 Contractor
SS NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0081841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/8/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627