WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76852
Permit No.
Basin 212

NOTICE OF INTENT NO. 15599

1. OWNER IDG, Inc.
MAILING ADDRESS 102 W. 500 South, Suite 200 Salt Lake City, UT 84101
ADDRESS AT WELL LOCATION 3240 N. Las Vegas Blvd

2. LOCATION N 1/2 NW 1/4 Sec. 18 T. 20 S/N R. 62 E/W CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 140-18-102-022 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thickness
Fill - Landscaping Sand		0	1	
CLAYEY SILT		1	14	
SILTY CLAY		14	23	
CLAYEY SAND		23	30	
SILTY CLAY		30	36	
CLAYEY GRAVEL		36	40	
SILTY CLAY		40	50	
SANDY CLAY		50	67	

DCNR/DWR Receipt OCT 4 1999 LAS VEGAS OFFICE

Date started 9/10, 1999
Date completed 9/10, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 67 Feet Depth Cased 67 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	67 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	67

Perforations:
Type perforation slotted screen
Size perforation .010 inch
From 47 feet to 67 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 45
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 45 feet to 67 feet

9. WATER LEVEL
Static water level 47.25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 4343 So. Polaris Ave (Contractor)
Las Vegas, Nevada 89104
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas N. Beall (By driller performing actual drilling on site or contractor)
Date 9-29-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627