WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76856
Permit No.
Basin 212

NOTICE OF INTENT NO. 19205

1. OWNER Paradise Development
MAILING ADDRESS 3111 S. Maryland Pkwy LV NV 89109
ADDRESS AT WELL LOCATION 3284 S. Maryland Pkwy

2. LOCATION SW ¼ SW ¼ Sec. 11 T 21 N/S R 61 E Clark County
PERMIT NO. ____ Issued by Water Resources | 162-11-401-006 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-5

Material	Water Strata	From	To	Thickness
Fill - Asphalt / Base		0	2	
SILTY SAND		2	6	
SILTY CLAY		6	10	
SANDY CLAY		10	12	
SILTY SAND		12	13	
SANDY CLAY	Y	13	15	
CLAYEY SAND	Y	15	24.5	

Date started 9/16, 1999
Date completed 9/16, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 24.5 Feet Depth Cased 24.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	24.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	24.5

Perforations:
Type perforation slotted screen
Size perforation .010 inch
From 9.5 feet to 24.5 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 24.5 feet

9. WATER LEVEL
Static water level 14.75 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 4343 So Polaris Ave. (Contractor)
Las Vegas Nv. 89103
Nevada contractor's license number issued by the State Contractor's Board ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944
Signed Thomas N. Beall (By driller performing actual drilling on site or contractor)
Date 9-27-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627