

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO: 41737

1. OWNER CLARK County Sanitation Dist ADDRESS AT WELL LOCATION DESERT INN @ STEPHANIE  
 MAILING ADDRESS 5857 FLAMINGO RD, CAS VEGAS, NEVADA 89122

2. LOCATION N 1/4 NE 1/4 Sec. 9 T. 21 N/S R. 62 E. CLARK County CLARK  
 PERMIT NO. DW-1105 Parcel No. 161-15-101-002 Subdivision Name DESERT INN RD @ STEPHANIE  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other Dewatering

4. PROPOSED USE dewater  
 Domestic  Municipal/Industrial  Irrigation  Test  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Bucket

6. 1-10 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BACK FILL DIRT		0'	7'	
SILT	13'	7'	20'	
SILTY SANDS		20'	23'	
SAND SMALL GRAVELS		23'	25'	
SILTY SANDS		25'	27'	
SILT HARD		27'	40'	

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
 From 22" To 40 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>Sch-40</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation 20 slot  
 Size perforation \_\_\_\_\_  
 From 40 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 40 feet to 0 feet

9. WATER LEVEL  
 Static water level 13' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality good

Date started 8-12, 1999  
 Date completed 8-17, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>10</u>	<u>1 HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FOOTHILL Eng. Anel Dewatering Contractor  
 Address 905 E. THIRD ST Contractor  
CORONA CA. 91719  
 Nevada contractor's license number 0035906 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2119  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-17-99