

OFFICE USE ONLY
 Log No. 76877
 Permit No. 162
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18017

1. OWNER Anthony Alosi ADDRESS AT WELL LOCATION 3281 W. Irene St
 MAILING ADDRESS 3281 W. Irene St Pahrump, NV 89048
 2. LOCATION NE 1/4 NE 1/4 Sec 12 T. 20S N/S R. 52E E. Nye County
 PERMIT NO. 27-542-03 Issued by Water Resources Parcel No. 03 #67338, Lot 2 Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
White clay		4	22	18
Brown clay		22	42	20
Grey clay	X	42	84	42
Soft brown clay	x	84	140	56

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17.4	.188	0	140

Perforations:
 Type perforation Torch cut
 Size perforation 1/4" wide x 8" Long
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 46 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Well Drilling Contractor
 Address 1060 W. Basin Rd. Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg By driller performing actual drilling on site or contractor
 Date September 26, 1999

Date started 9/7/99, 19____
 Date completed 9/9/99, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 minutes

