WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76895
Permit No.
Basin 107

NOTICE OF INTENT NO. 37601

1. OWNER William Weaver
MAILING ADDRESS 510 Hwy 338
Wellington, Nev, 89444

ADDRESS AT WELL LOCATION Lower Colony Rd. #3 AKA 12 Santa Sapina
Wellington, Nev 89444

2. LOCATION SW ¼ NW ¼ Sec. 22 T 11 N/S R 23 E Lyon County
PERMIT NO. Issued by Water Resources | 10-291-21 Parcel No. | Santa Theresa Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D. S. Top Soil		0	5	5
Hard pan		5	8	3
Yellow Sandy Clay		8	28	20
Sand	yes	28	55	27
Sandy Clay		55	84	29
Fine Sand + Coarse Sand	yes	84	120	36

Date started June 3, 1999
Date completed June 6, 19..

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	3

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6	Inches	50	Feet	120	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6/5/8		188	0	120

Perforations:
Type perforation Factory Saw Slot
Size perforation 3/32 x 3
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling Contractor
Address P.O. Box 92 Contractor
Smith, Nev, 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date 6-22-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627