

OFFICE USE ONLY  
 Log No. 76902  
 Permit No. 105  
 Basin 1

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3/1485

1. OWNER GM Custom Builders ADDRESS AT WELL LOCATION 1019 Stephanie Ln.  
 MAILING ADDRESS Gary Mathers Construction Minden NV 89423  
Gardnerville W. 89410  
 2. LOCATION NW 1/4 NW 1/4 Sec. 32 T. 14 S. R. 20 E Douglas County  
 PERMIT NO. 21-290-72 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Blow SANDS and Surface water		3	27	24
DG SANDS and small Gravels		24	48	24
DG SANDS		48	90	42
Brown Sandy Clay		90	115	25
Brown Clay SOAMS to 125' then coarse DG SANDS and small Gravels	XX	115	140	25

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 16 3/4 Inches To 0 Feet  
 From 0 Feet To 140 Feet  
 From 0 Feet To 140 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.02</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3 x 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 7-26, 1999  
 Date completed 7-28, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>35</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Capital City Well Drilling Contractor  
 Address 20 Kit Kat DR. Contractor  
Carson City NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Z. Shack by driller performing actual drilling on site or contractor  
 Date 8/1/99