WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76909
Permit No.
Basin 108

NOTICE OF INTENT NO. 27281

1. OWNER Ida Favor
MAILING ADDRESS 188 N. Hwy 95-A
Yerington NV 89447
ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 14 N S R 25 E — Lyon County
PERMIT NO. — Issued by Water Resources
14-212-08 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clayish		0	4	4
Coarse Sand		4	18	14
Bluish Gray Clay - Gravel		18	22	4
Bluish Gray Clay - Coarse Sand - Gravel		22	57	35
Bluish Gray Clay - Coarse Sand		57	62	5
Coarse Sand Gravel		62	68	6
Brown clay - Coarse Sand		68	96	28
Fine Sand		96	100	4
Brown clay		100	101	1
Coarse Sand - Gravel	X	101	114	13
Brown clay		114	119	5

Date started 2-7, 1985
Date completed 2-12, 1985

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	316"	1 HR
Air Lift	50	100 line	1 HR

8. WELL CONSTRUCTION
Depth Drilled 119 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10 5/8	0	119

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	119

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 99 feet to 119 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 119 feet

9. WATER LEVEL
Static water level 16 ft feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden
By driller performing actual drilling on site or contractor
Date 6-26-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627