WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76906
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER James Ammons
MAILING ADDRESS P.O. Box 137
Yerington NV 89447

ADDRESS AT WELL LOCATION 18 Dove Ln.
Yerington NV 89447

2. LOCATION SW ¼ SE ¼ Sec. 34 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 14-381-33 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Coarse Sand & Gravel		4	12	8
Coarse Sand & Gravel & Clay		12	18	6
Coarse Sand & Gravel		18	26	8
Clay & Sand		26	38	12
Coarse Sand-Gravel-Clay		38	52	14
Coarse Sand-Gravel		52	58	6
Clay-Coarse Sand		58	76	18
Coarse Sand-Gravel	X	76	105	29
Coarse Sand-Gravel-Clay Tight		105	125	20
Coarse Sand-Gravel	X	125	140	15
Hard Brown clay		140	151	11
Brown clay		151	159	8
Coarse Sand-Gravel	X	159	170	11
Brown clay-Sand		170	174	4
Coarse Sand-Gravel with Red Clay	X	174	179	5

Date started 3-10, 19 98
Date completed 3-16, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	50	120' AIR line	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 179 Feet Depth Cased 180' 9" Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	179 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1.5	179

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 125 feet to 140 feet
From 159 feet to 179 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 179 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Lane (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed B Ogden (By driller performing actual drilling on site or contractor)
Date 5-31-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627