WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76915
Permit No.
Basin 104

NOTICE OF INTENT NO. 34828

1. OWNER Albert (Rusty) Hendrick
MAILING ADDRESS 18 Heaven Hill Way
Carson City, NV 89706

ADDRESS AT WELL LOCATION 18 Heaven Hill Way

2. LOCATION NW 1/4 SE 1/4 Sec. 31 T 16N N/S R 20E E Carson County
PERMIT NO. _____ Issued by Water Resources | 08-023-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we installed a 5 1/2" OD PVC Sch 80 liner. We have .020 screen from 150'-90'. Blank from 90' to 10'. Gravel pack from 150'-70'. Cement from 70'-10'. This was an 8 5/8" cased well that had a broken casing about 40' from surface.				

Date started 09/24/1999 , 19__
Date completed 09/24/1999 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
27	33	1 Hr

8. WELL CONSTRUCTION
Depth Drilled 151 Feet Depth Cased 150.6 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 1/2"		Sch 80	10	150

Perforations:
Type perforation Factory screen
Size perforation .020 slot
From 90 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 150 feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 09/25/99

USE ADDITIONAL SHEETS IF NECESSARY