WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76917
Permit No.
Basin 177

NOTICE OF INTENT NO. 30872

1. OWNER Ralph Lorraine Hines
MAILING ADDRESS 13179 E Hwy 160
Alamosa, Co. 81101-9532

ADDRESS AT WELL LOCATION 2586 N 21W

2. LOCATION NW ¼ NE ¼ Sec. 22 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 5-591-05 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	
gravel cobbles clay		3	30	
clay		30	33	
gravel conglomerate		33	42	
clay		42	47	
gravel con.		47	49	
clay		49	57	
gravel con.		57	60	
Sandy clay		60	80	
gravel	water	80	81	
Sandy clay		81	93	
gravel	water	93	95	
Sandy clay		95	102	
gravel	water	102	103	
Sandy clay		103	112	
gravel	water	112	113	
Sandy clay		113	125	
gravel	water	125	126	
Sandy clay		126	129	
gravel	water	129	130	
Sandy clay		130	137	
gravel	water	137	138	
Sandy clay		138	141	

Date started July 21, 1999
Date completed July 28, 1999

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	3'	1 hr

8. WELL CONSTRUCTION
Depth Drilled 141 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10	Inches	0 Feet	55 Feet
8	Inches	55 Feet	141 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	141

Perforations:
Type perforation mill
Size perforation 8 x 2.5" x 6 row
From feet to feet
From 89 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 52 feet to 141 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Orvan R Maynard (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard (By driller performing actual drilling on site or contractor)
Date July 29-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627