

OFFICE USE ONLY  
 Log No. 76918  
 Permit No. 87  
 Basin SW Reno

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42807

1. OWNER STEVE RYCKEBOSCH ADDRESS AT WELL LOCATION 7287 Lakeside Drive  
 MAILING ADDRESS 11350 Castlewood Ct. Reno, Nevada 89511  
 2. LOCATION NE 1/4 NE 1/4 Sec 2 T 18N N/S R 19 E Washoe County  
 PERMIT NO. 222-060-05 SW Reno  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other..MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil, smaller boulders & gravels		0	2	2
Boulders & gravel with brown clay		2	24	22
Granite boulder		24	27	3
Gravels with brown to rusty clays		27	63	36
Black volcanic rock		63	70	7
Smaller boulders & gravels with brown clay		70	108	38
Volcanic rock with clay streaks		108	129	21
Soft zone	X	129	132	3
Volcanic rock with clay streaks		132	177	45
Brown clay		177	178	1
Sand & gravel	X	178	181	3
Brown sticky clay		181	191	10
Multi-color volcanic rock		191	204	13
Fracture	X	204	207	3
Multi-color volcanic rock		207	238	31
Soft zone	X	238	241	3
Multi-colored volcanic rock		241	274	33
Soft fracture zone	X	274	283	9
Multi-colored volcanic rock		283	290	7

8. WELL CONSTRUCTION  
 Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 290 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	290

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 130 feet to 150 feet  
 From 170 feet to 210 feet  
 From 230 feet to 250 feet  
 From 270 feet to 290 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100 foot  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 100 feet to 290 feet

9. WATER LEVEL  
 Static water level 114 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date August 14, 1999

Date started Aug 2, 1999  
 Date completed Aug 11, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>		