

Log No. 76936
 Permit No. 92A
 Basin 92A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32812

1. OWNER Jim & Jean Stewart ADDRESS AT WELL LOCATION 10605 N. Virginia
 MAILING ADDRESS 13915 Red Rock Road Reno, NV 89506
 2. LOCATION SE 1/4 SW 1/4 Sec. 1 T. 20 N. R. 18 E. Washoe County
 PERMIT NO. 63856 Issued by Water Resources Parcel No. 081-031-47 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders, clay, and Gravel		0	163	
White Clay		163	168	
Gravel and Rocks		168	171	
Gray Clay		171	193	
Black Rock		193	220	
Brown Clay & Gravel		220	254	
Gray Clay & Gravel		254	300	
Gray Rock		300	305	
Gray Clay & Shale		305	390	
Gray Sandstone		390	400	
Gray Clay		400	431	
Gray Sandstone		431	445	
Gray Clay		445	494	
Gray Sandstone		494	495	
Gray Clay		495	542	
Gray Sandstone		542	545	
Gray Clay		545	570	
Gray Sandstone		570	574	
Gray Clay		574	602	
Additional Perforated Casing:				
		480	500	
		540	580	

8. WELL CONSTRUCTION
 Depth Drilled 602 Feet Depth Cased 602 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>1 1/4</u> Inches	<u>0</u> Feet <u>19</u> Feet
<u>9 7/8</u> Inches	<u>19</u> Feet <u>602</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>-1</u>	<u>602</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 1/8" x 3"
 From 140 feet to 160 feet
 From 200 feet to 250 feet
 From 300 feet to 320 feet
 From 380 feet to 400 feet
 From 420 feet to 440 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 602 feet

9. WATER LEVEL
 Static water level Artesian feet below land surface
 Artesian flow 2 G.P.M. 2 P.S.I.
 Water temperature COOL °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MILLER & SONS DRILLING CO.
 Contractor
 Address P.O. BOX 8056 Reno, NV 89507
 Contractor

Date started 01-14-99, 19____
 Date completed 2-12-99, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	<u>25</u>	<u>600</u>	<u>4</u>

Nevada contractor's license number issued by the State Contractor's Board 37915
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 2-27-99