

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **19826**

1. OWNER **GIAMBALVO, PAUL** ADDRESS AT WELL LOCATION **2810 LORELEI**  
 MAILING ADDRESS **2810 LORELEI**  
**PAHRUMP, NV 89048**

2. LOCATION **SE** 1/4 **NE** 1/4 Sec. **12** T **21S** N/S R **53E** E **NYE** County  
 PERMIT NO. **44-521-13** Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	60	
CALICHIE	WB	60	73	13
CLAY		73	92	19
CALICHIE	WB	92	104	12
CLAY		104	118	14
CALICHIE	WB	118	134	16
CLAY		134	153	19
CALICHIE	WB	153	167	14
CLAY		167	185	18
CALICHIE	WB	185	198	13
CLAY		198	225	27
CALICHIE	WB	225	240	15
CLAY		240	270	30
CALICHIE	WB	270	295	25
CLAY		295	320	25
CALICHIE	WB	320	335	15
CLAY		335	370	35
CALICHIE	WB	370	400	30

GRAVEL PACKED FROM 400 FT TO 220 FT WITH PEA GRAVEL. FROM 220 FT TO 215 FT PACKED WITH BENTONITE PELLETS 3/4. FROM 215 FT TO 50 FT A MIXTURE OF PEA GRAVEL AND BENTONITE PELLETS WERE Poured.

8. WELL CONSTRUCTION  
 Depth Drilled **400** Feet Depth Cased **400** Feet

HOLE DIAMETER (BIT SIZE)  
 12.25 Inches From 0 Feet To 400 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	400

Perforations:  
 Type perforation **SAW CUT**  
 Size perforation **1/8 X 3**

From **280** feet to **380** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal **50**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **400** feet

9. WATER LEVEL  
 Static water level **66** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV. 89048**

Date started **8/30/99** . 19\_\_\_\_  
 Date completed **9/3/99** . 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailor	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Nevada contractor's license number issued by the State Contractor's Board **47333**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed *Thomas D...*  
 By driller performing actual drilling on-site or contractor

Date **9/16/99**